for CT, CTS, CTSE inserts

support for rail mounting **DIN EN 60715**



CT/CTS/CTSE inserts coupling screws cable-clamping plates




description	part No.	part No.
supports for CT, CTS, CTSE inserts	CT APE	
bush for CT, CTS, CTSE inserts screw pin for CD, CNE, CCE, CSH inserts		CRBF CRBM
straight cable clamping plate angled cable clamping plate		CRAD CRAS

CT APE

Coupling screws for CT/CTSE inserts


The use of CRBF (female) and CRBM (male coupling screws is recommended to guarantee a stable and safe coupling between inserts (without enclosures) with terminal blocks and inserts without terminal blocks.




EN 60715 C 30 EN 60715 G 32

EN 60715

TH 35-7,5 and TH 35-15





CRAD

CRAS

29,2

for conductor groups or cable with \emptyset min = 12 mm and \emptyset max = 23 mm

Use of cable-clamping plates

In accordance with the recommendations of standard IEC 60352-2, the weight of the conductor groups or multipolar cables must not cause any stress on the contacts inside the inserts. It is therefore advisable to use cable-clamping plates in those inserts without enclosures.



ACCESSORIES