



41

1.6



D

С

A device employing a 15 A or 20 A grounding type receptacle but no supplementary protector shall be protected by a fuse or circuit breaker that does not exceed the marked rating of the receptacle in the end use. When a fuse or circuit breaker rated less than the receptacle's rating is provided, a Marking shall be provided to indicate the maximum ampere rating of the protection provided.

These devices shall be mounted on enclosures having adequate strength and thickness and with adequate spacing provided. Seal rating is based on mounting to a surface that is clean, flat and smooth.

36

.4

| PIC RATINGS/SPECIFICATIONS | | |
|-----------------------------------|-----------------------|-------------|
| | | |
| | 125V | |
| | 15A | |
| | 10kA | |
| JL EN 60529: | 4, 12 IP65 | |
| THICKNESS: | 5.0mm max | |
| ING SCREW TORQUE: | 0.8N-m | |
| IAL BLOCK TORQUE: | 0.5N-m | |
| NG POWER WIRE SIZE: | 0.25 - 2.5 sq mm / 24 | 4-12AWG |
| TRIP LENGTH: | 7 - 8 mm | |
| | | |
| 01/17/2019 IVILINCO | | |
| DCG TITLE: | | |
| 05/15/2019 | | A A |
| DHDP-8M-RJ45-32 | | |
| | | |
| : | | |
| SIZE DWG. NO. | | REV |
| B DHDP-8M-RJ45-32 D | | |
| SCALE: 2:3 WEIC | GHT: S | HEET 1 OF 1 |
| 2 |] | |