

A device employing a 15 A or 20 A grounding type receptacle but no supplementary protector shall be protected by a fuse or circuit breaker that does not exceed the marked rating of the receptacle in the end use. When a fuse or circuit breaker rated less than the receptacle's rating is provided, a Marking shall be provided to indicate the maximum ampere

These devices shall be mounted on enclosures having adequate strength and thickness and with adequate spacing provided. Seal rating is based on

> PIC RATINGS/SPECIFICATIONS 125V 15A 10kA 4, 4X, 12 | IP65 M4 (8-32) (304 or 316SS for 4X) 1.2~1.8N-m (0.9~1.3 Lb-Ft) 0.5 ~ 4.0 sq mm / 20-12AWG 10 ~ 11 mm MENCOM CORPORATION SMPLX; USB-AB; 16 DWG. NO. REV B DP1-USB-AFBF-16LS WEIGHT: SHEET 1 OF 1 1

С

D