


These devices shall be mounted on enclosures having adequate strength and thickness and with adequate spacing provided. Seal rating is based on mounting to a surface that is clean, flat and smooth.

HOUSING MATERIALS		SCCR:		0.2kA	
BODY:	EPOXY COATED DIE CAST ALUMINUM	NEMA/UL EN 60529:		4, 4X, 12 IP65	
GASKET:	THERMOPLASTIC ELASTOMER	MOUNTING SCREW SIZE:		M4 (8-32) (304 or 316SS for 4X)	
HANDLE:	POLYAMIDE	MOUNTING SCREW TORQUE:		1.2~1.8N-m (0.9~1.3 Lb-Ft)	
LEVERS:	STAINLESS STEEL	INCOMING POWER WIRE SIZE:		0.5 ~ 4.0 sq mm / 20-12AWG	
		WIRE STRIP LENGTH:		10 ~ 11 mm	
 I WASHER, M4 NUT		UNLESS OTHERWISE SPECIFIED:		<div>MENCOM CORPORATION</div> <div>TITLE: GFI; 15A; 32</div>	
		DRAWN BY DCG			
		DRAWN DATE 11/21/2018			
		CHECKED BY GO			
		CHECK DATE 11/26/2018			
		COMMENTS:			
		MATERIAL		SIZE DWG. NO. REV	
		FINISH		B GF-15R-32 E	
		DO NOT SCALE DRAWING		SCALE: 2:3 WEIGHT: SHEET 1 OF 1	