

2

A device employing a 15 A or 20 A grounding type receptacle but no supplementary protector shall be protected by a fuse or circuit breaker that does not exceed the marked rating of the receptacle in the end use. When a fuse or circuit breaker rated less than the receptacle's rating is provided, a Marking shall be provided to indicate the maximum ampere rating of the protection provided.

These devices shall be mounted on enclosures having adequate strength and thickness and with adequate spacing provided. Seal rating is based on mounting to a surface that is clean, flat and smooth.

SS/SPECIFICATIONS	
125\/	
15A	
10kA	
4, 4X, 12 IP65	
M4 (8-32) (304 or	316SS for 4X)
1.2~1.8N-m (0.9~	
	/ 20-12AWG
10 ~ 11 mm	
COM CORPC	RATION
GE: DB9: 32	
01,22,,02	-
NO.	REV
GF-DB9-32	F
WEIGHT:	SHEET 1 OF 1
	1
	125V 15A 10kA 4, 4X, 12 IP65 M4 (8-32) (304 or 1.2~1.8N-m (0.9~ E: 0.5 ~ 4.0 sq mm 10 ~ 11 mm COM CORPC GF; DB9; 32 NO. GF-DB9-32

С

D

1