

В

NOTE: SCREW TERMINAL CONNECTION, PLUG AND SOCKET ARE BOTH SUPPLIED

1

D

С

2

A device employing a 15 A or 20 A grounding type receptacle but no supplementary protector shall be protected by a fuse or circuit breaker that does not exceed the marked rating of the receptacle in the end use. When a fuse or circuit breaker rated less than the receptacle's rating is provided, a Marking shall be provided to indicate the maximum ampere rating of the protection provided.

These devices shall be mounted on enclosures having adequate strength and thickness and with adequate spacing provided. Seal rating is based on mounting to a surface that is clean, flat and smooth.

PIC RATINGS/SPECIFICATIONS

125V 15A 10kA NEMA/UL | EN 60529: 4, 12 IP65 PANEL THICKNESS: 5.0mm max 0.8N-m MOUNTING SCREW TORQUE: TERMINAL BLOCK TORQUE: 0.5N-m INCOMING POWER WIRE SIZE: 0.25 - 2.5 sq mm / 24-12AWG WIRE STRIP LENGTH: 7 - 8 mm DCG MENCOM CORPORATION 11/21/2018 TITLE: GO

GF; DB9-PC9; NR; 32



1