



(X4) USE PH2 SCREW
DRIVER ON MOUNTING
SCREWS. (REF. MOUNTING
SCREW TORQUE)

ROTATE TWO TURNS COUNTER
CLOCKWISE TO RELEASE THE
TURN BUCKLE PRIOR TO TIGHTENING

TURN BUCKLES ROTATE 90 DEG. INTO
THEIR CLAMPING POSITION AS
MOUNTING SCREWS TIGHTEN.
DO NOT OVER-TORQUE!

These devices shall be mounted on enclosures having adequate strength and thickness and with adequate spacing provided. Seal rating is based on mounting to a surface that is clean, flat and smooth.



| PIC RATINGS/SPECIFICATIONS | |
|----------------------------|-----------------------------|
| VOLTS: | 125V |
| AMPS: | 3A |
| SCCR: | 0.2kA |
| NEMA/UL EN 60529: | 4, 12 IP65 |
| PANEL THICKNESS: | 5.0mm max |
| MOUNTING SCREW TORQUE: | 0.8N-m |
| TERMINAL BLOCK TORQUE: | 0.5N-m |
| INCOMING POWER WIRE SIZE: | 0.25 - 2.5 sq mm / 24-12AWG |
| WIRE STRIP LENGTH: | 7 - 8 mm |

| | |
|--|--------------------|
| OPERATING TEMPERATURE: (-10°C / +60° C (+14° F / +140° F)) | |
| HOUSING MATERIALS | |
| BODY: | NICKEL PLATED ZINC |
| GASKETS: | PUR FIPG |
| FRONT COVER: | POLYCARBONATE |
| LATCH & LOCK: | PBT |
| BACK COVER: | POLYPROPYLENE |
| UNLESS OTHERWISE SPECIFIED: | |
| DIMENSIONS ARE IN INCHES AND [MM] | |
| MATERIAL | |
| FINISH | |
| DO NOT SCALE DRAWING | |

| | | | |
|------------------------|---------------|--------------------|--|
| DRAWN BY: DG | | MENCOM CORPORATION | |
| DRAWN DATE: 08/03/2020 | | | |
| CHECKED BY: DCG | | | |
| CHECK DATE: 08/03/2020 | | TITLE: | |
| | | GFI; RJ45; R; LP3 | |
| SIZE | DWG. NO. | REV | |
| B | LP3-GF-RJ45-R | B | |
| SCALE: 1:2 | WEIGHT: | SHEET 1 OF 1 | |

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MENCOM CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MENCOM CORPORATION IS PROHIBITED.